

BUILDING INSPECTION NOTICE

P-4. Complete

Permit #: 1 9 - 1 1 4 0 0 6 - M F

LI:

Supervisor Tel: 408 535-7743

Confirmation #: 0 1 4 6 5 9 2 6

Received: 04/11/2019

By: Phone

Preferred:

Scheduled:	0	4	/	1	5	/	1	9
------------	---	---	---	---	---	---	---	---

Tract: 6407

Lot:

of Units:0 Map: 874 H 4, 874 H 3

Address: 537 GIUFFRIDA AV UNIT B SAN JOSE , UNIT(S) B

Contact: John

Phone: (408) 927-9999

ETA Call: Y

Owner: SIMMERMAN PAMELA M AND GOMEZ GABRIELA A

Contractor: DWC PLUMBING INC

(408)927-9999

Folder Name: (P 100%) REPIPE CONDO UNIT Subtype: Condo

Work Proposed: Sub-Trades Only

Comments:

Related Permits:

Insp Time:

Inspection time listed at the left includes 10 minutes travel time.

Next Inspections Suggested

Number of Units:

Time inspection completed

[illegible]

Inspection Code: OK = Approved, PA = Partial Approval, CN = Correction Notice, NR = Not Ready, NN = Not Necessary, RF = Re-Inspection Fee Due

Remarks: Pan drain to discharge independently

Insulate all 3/4 and larger hot water and source to kitchen sink

Patch all wall

You have a total of 0.5 hour(s) remaining on this project as of Friday, April 12, 2019 12:01:24 PM.

Inspector's Signature:

Print:

BMASKHAL

Date: 04 / 15 / 19

Page: 1 of 1